



BLITZTAC FIRE MONITOR AND BRACKET FIELD TEST

Team	Date:
------	-------

Team Member:

Demerit: 2 demerits for each omission
--

For Failure to:	Demerit
-----------------	---------

Blitztac Fire Monitor

1	Ensure there is no damage to the Blitztac Fire monitor including dents, cracks, corrosion, missing, broken or loose parts, or other defects	
---	---	--

2	Ensure the waterway is clear of obstructions	
---	--	--

3	Ensure the gaskets are in good repair	
---	---------------------------------------	--

4	Ensure the 2.5" to 1.5" adapter is installed	
---	--	--

5	Ensure the folding legs are free of damage and that they open and close	
---	---	--

6	Ensure the valve handle locks when closed and releases	
---	--	--

7	Ensure the Shut-Off valve is operational, test full range of motion	
---	---	--

8	Ensure the outlet pivots smoothly	
---	-----------------------------------	--

Mounting Bracket and Arm

9	Ensure there is no damage to the mounting bracket and arm including dents, cracks, corrosion, missing, broken or loose parts, or other defects	
---	--	--

10	Ensure all pins are present and free from damage	
----	--	--

11	Ensure "T" handle bolts thread into the mounting arm	
----	--	--

12	Repack and report to captain	
----	------------------------------	--

Total Demerits:	
-----------------	--

Signature of Judge
